# STOP GLOBE VALVE ACID-PROOF TYPE ZSA400

## **CHARACTERISTIC:**

Diameter 10 -100 mm: Pressure 400 bar;

Temperature up to 250°C for acids, bases and other aggressive media;

up to 550°C for non-toxic media; (with PTFE sealing up to 200°C);

Medium acids, liquors, water, steam and other non-toxic and non aggressive liquid and

gas media, engine fuel.

**VERSIONS:** type / ends / body material / disc and disc ring / drive type

ZSA400 / --- / --- / ---Example: Example: ZSA400 / SW / L / ---

Type - body material	Sign
X6CrNi18-10 or GX5CrNi19-10	ZSA400
X2CrNiMo17-12-2 or GX5CrNiMo19-11-2	ZSB400

Ends	Sign
Standard - BW	
Socket weld	SW
Flanged	K

Disc and disc ring	Sign	
Standard		
Stellit	L	


Others	Sign

### **APPLICATION:**


Stop globe valve (ZSA400) is designed to open and stop the flow. The valve is not supposed to be used as a regulating device. For regulation the version with throttling plug should be applied.


DN 10 ÷ 15


DN 20 ÷ 50




DN 65 ÷ 100













FABRYKA ARMATURY PRZEMYSŁOWEJ

WAKMET Sp. z o.o.

Bodzanów 75 48-340 GŁUCHOŁAZY tel.+48 77 439-40-20. fax +48 77 439-18-72

wakmet@wakmet.com.pl

www.wakmet.com.pl

#### **MATERIALS:**

Versions	ZSA400	ZSB400	ZSA400	ZSB400							
Parts	DN 1	15 - 65	DN 80 - 100								
Body, bonnet	X6CrNiTi18-10 (1.4541)	X2CrNiMo17-12-2 (1.4404)	GX5CrNi19-10 (1.4308)	GX5CrNiMo19-11-2 (1.4408)							
Disc	X6CrNiTi18-10 (1.4541)	X2CrNiMo17-12-2 (1.4404)	X6CrNiTi18-10 (1.4541)	X2CrNiMo17-12-2 (1.4404)							
Stem	X6CrNiTi18-10 (1.4541)	X2CrNiMo17-12-2 (1.4404)	X6CrNiTi18-10 (1.4541)	X2CrNiMo17-12-2 (1.4404)							
Packing rings, gasket	Grafit										
Wheel	Cast iron										

Special materials on request; modifications reserved.

#### **DIMENSIONS:**

	Sta				Flanged "K"												
DN	d	Dz	Dw	L	Weight	Н	h	Dk	Dz	Dp	Do	do	n	L	g	f	
10	10	20	10			005	4.0	222	-	-	-	-	-	-	-	-	
15	14	28	17	160	3,00	205	5 12	2 200	145	45	100	22	4	240	30	2	
20	20	35	21,5	160	7.50	266	19	000	-	-				260			
25	24	44	29		7,50			200	180	68	130	26	4	260	38	2	
32	30	50	33						-	-				300			
40	38	62	40	300	29,00	418	8 23	23	500	220	88	165	30	4	300	48	3
50	44	77	49,5						235	102	180	30	8	350	52	3	
65	62	91	62	340	41,00	714	45	GNR 700	290	122	225	33	8	400	64	3	
80	76	117	81	380	83,00	637	36	GNR 500	305	138	240	33	8	450	68	3	
100	92	144	102	430	125,00	720	50	GNR 500	370	162	295	39	8	520	80	3	

Dimensions in mm; modifications reserved.

## **TECHNICAL DATA:**

			-															
		DNI	Nominal working pressure at working temperature															
Body material	Medium	PN	20°C	100°C	150°C	200°C	250°C	300°C	350°C	400°C	450°C	480°C	500°C	510°C	520°C	530°C	540°C	550°C
-		bar																
X6CrNiTi18-10 (1.4541)	Aggressive	400	400	396,3	373,4	354,3	337,1	-	-	-	-	-	-	-	-	-	-	-
<b>GX5CrNi19-10</b> (1.4308)	media	400	400	304,9	271,4	238,0	223,0	1	-	-	-	1	1	-	-	-	1	-
<b>X6CrNiTi18-10</b> (1.4541)	Non	400	400	396,3	373,4	354,3	337,1	318,0	306,6	297,1	290,6	285,5	283,7	282,9	282,0	281,4	280,6	270,5
GX5CrNi19-10 (1.4308)	Aggressive media	400	400	304,9	271,4	238,0	223,0	209,4	195,1	180,9	166,6	158,3	152,3	-	-	-	-	-

#### **MOUNTING AND OPERATING:**

The valve can only be mounted and operated by skilled, properly trained and qualified personnel. Incorrect assembly or operation of the valve may have substantial impact on the entire system such as fluid leakage, reduction in system's function etc.

Before a valve is installed the pipeline must be clean from any mechanical impurities. The compatibility of critical parameters of the flow must be checked with the parameters of the valve. Stop globe valve can be mounted to a pipe-line in any position. The direction of flow should only comply with the arrow marked on the body. The valve should be operated strictly with its assign. In order to provide valve's reliability the following suggestions must be observed:

- medium flowing through the valve is supposed to be clean out of any mechanical impurities;
- the valve must be protected from any mechanical damages during its work;
- nominal parameters marked on the valve must be observed.